

Contracts Management

Date: June 6, 2013
To: Potential Offerors
From: Gary L. Callahan, Senior Contracts Manager
Re: **Solicitation Addendum # 2 to RFP 13-0637 / East Hawaii Region
Design-Build Turnkey Angiography Suite**

This correspondence serves as Addendum # 2 to the subject Request for Proposals (“RFP”). Your response to this RFP should be governed by the content of the original RFP and the revisions / corrections / additions / clarifications provided in this addendum notice.

Please note that the *“Submission Deadline for Questions & Clarification Requests”* is being changed by this addendum below to:

3:00 PM, HST, Monday, July 15, 2013

The Request for Proposals shall be amended to include the following two (2) changes:

1. The Procurement Timeline, **Section 1.2** on page 4, is hereby deleted & replaced with the following:

ACTIVITY	SCHEDULED DATES
1. RFP Issued & Public Announcement	May 14, 2013
2. MANDATORY Pre-Proposal Meeting including Site Visit	May 29, 2013
3. Closing Date for Receipt of Questions	July 3, 2013
4. Addendum - HHSC Response to Offerors’ Questions (if needed)	July 8, 2013
5. Closing Date for Receipt of Proposals	July 15, 2013 - No Later than 3:00 PM, HST
6. Mandatory Requirements Evaluation	July 15, 2013
7. Proposal Evaluations	July 15- August 9, 2013
8. Proposal Discussions & Presentations (optional)	July 22 –August 2, 2013,
9. Best and Final Offers (optional)	July 30 – August 8, 2013
10. Contractor Selection/Award Notification (on/about)	August 10, 2013
11. Contract Tentative Award Date	August 12, 2013
12. Contract Tentative Start Date	August 15, 2013

2. Section 2.0, INTRODUCTION, on page 6 of the RFP is hereby deleted in its entirety and replaced with the following:

2.0 INTRODUCTION.

“The Hilo Medical Center (HMC) is looking to replace their existing angiography suite with a multipurpose suite that will serve neurology, cardiology, vascular and interventional services. The design intent for the room is best described as a cardiac-cath lab with anesthesia capabilities and Operating Room ventilation as defined under the Facility Guidelines Institute (link to read-only copy below) and published by the American Society for Healthcare Engineering (2010 Edition). The design parameters for the ventilation will match FGI guidelines for OR room, with the minimum outdoor of four (4) air changes per hour and the minimum total of twenty (20) air changes per hour. The required station outlets for oxygen, vacuum and medical air systems will be 2 / 4 / 1 / 1 pursuant to the anesthesia related FGI Guidelines. An area has been identified in the hospital for the room. It has also been determined to request the manufacturing vendors of the required equipment to provide a turn-key design-build multipurpose suite in that space. The CONTRACTOR must be able to demonstrate experience with similar design-build projects and proven compliance with all of the project’s federal, state, and county requirements.”